



KOMO®
Product certificate
K106169/01



Issued 2022-10-01 Replaces -
Valid until Indefinite Dated
Page 1 of 2

Mainpipe
MAINCOR Rohrsysteme GmbH & Co. KG

STATEMENT BY KIWA

This product certificate is based on Guideline/BRL 5611 "Plastics piping systems of PE-RT/Al intended for heating installations: radiator connections" dated 25 October 2016, issued according to the Kiwa-Regulation for Certification.

The quality system and the product characteristics of this product are checked periodically. Based on this, **Kiwa declares that** there is legitimate confidence that:

Upon delivery, the product supplied by the certificate holder meets the requirements:

- Of the technical specifications laid down in this product certificate,
- The product requirements laid down both in this product certificate and in the Guideline/BRL.

Provided the product is accompanied by the KOMO® quality mark in the manner set out in this product certificate.

Ron Scheepers
Kiwa

This product certificate is only valid in combination with a KOMO certified plastics piping system.

This product certificate is also included on the KOMO foundation websites: www.komo.nl and www.komo-online.nl.

Users of this product certificate is advised to check whether it is still valid. For this purpose consult the website of Kiwa: www.kiwa.nl.

Kiwa Nederland B.V.
Sir Winston Churchilllaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Certificate holder
MAINCOR Rohrsysteme GmbH & Co. KG
Silbersteinstraße 14
97424 SCHWEINFURT
Germany
Tel. +49 (0)9721 / 65977 - 100
Fax +49 (0)97 21 / 65977 - 200
info@maincor.de
www.maincor.de



Assessed is:
• Quality system
• Product
Periodic control

Mainpipe

TECHNICAL SPECIFICATION

Subject

Mainpipe

Product characteristics

The product complies to BRL 5611 Plastics piping systems of PE-RT/Al intended for heating installations: radiator connections.

Specification

The dimensions of the pipe in the table below are part of this certificate.

Nominal outside Diameter (mm)	Wall thickness (mm)	Wall thickness Aluminium (mm)
16	2,0	0,20
20	2,25	0,22
25	2,5	0,30
32	3,0	0,33

Colour: White outside / White inside.

Marking

The products shall be marked with the KOMO® mark.

Pipes

The minimum required marking on the pipes shall be:

- KOMO (or KOMO® word mark) + class 5/ 10 bar;
- material identification: PE-RT type 2;
- the build up of the pipe; PE-RT/Al/PE-RT;
- certificate number of accompanying technical approval-with-product certificate of the piping system;
- the manufacturer's name, trade name, system name or logo;
- nominal outside diameter and nominal wall thickness of the pipe in mm;
- production code.

The realization of the marks is as follows: clear, durable and indelible at intervals of not more than 2 meters.

Logistics

Production and assembly of the system is laid down in the annex of the certification agreement.

APPLICATION AND USE

The products are intended to be used for piping systems for heating installations: radiator connections and floor heating systems with a lifetime of 50 years at an operating temperature profile according to class 5 of ISO 10508 and an allowable working pressure of maximum 10 bar.

TIPS FOR THE USER

Check on delivery of the products listed under the "technical specification" whether:

- The product(s) and material(s) ordered are delivered in accordance with the agreement you made.
- The brand and the method of marking is correct
- No defects or damage is visible (for example, resulting from the transportation).

If on the basis of the foregoing you decide to proceed to rejection, please contact

- MAINCOR Rohrsysteme GmbH & Co. KG

And if necessary,

- Kiwa Nederland B.V.

Carry out the storage, transport and processing in accordance with the provisions included in this product certificate and/or documents of the certificate holder.

